

- 1995/2006 Seagrave Marauder tillered aerial ladder (aerial/trailer are 1995 and tractor is 2006). This unit is not functional (the aerial failed annual testing in December 2018) and is in poor body shape and mechanical shape.
- 1988 Mack pumper; model: MC686FC. The unit is mechanically and body shape condition of "fair"; however, it has not been annually tested and/or maintained in 3 years.
- 2006 KME/Smeal pumper; model: HME MFDxl-12. The unit has a 1,500 gallon-per-minute pump and a 500-gallon water tank. The unit is in mechanically fair condition and was passed annual testing in October 2019. The unit has multiple body issues and I would list the body condition as "poor."
- 1969 Seagrave pumper. The unit has a 1,500 gallon-per-minute pump. It has not been maintained nor tested in at least 4 years. It is in mechanically and body-shape "poor" condition.
- 2006 US Army-surplus 5-ton, diesel powered truck. This apparatus does not run and needs mechanical repairs to become operation.
- Seven Scott NXG7 self-contained breathing apparatus, 4,500 PSI bottles (30-minute capacity). These units are in various stages of functionality; but all required repairs are minor -Numerous broken and/or unusable hand tools (axes, pike poles, etc.)
- Eighteen (18) 4,500 PSI, 30-minute SCBA bottles that have exceeded their 15-year, DOT regulated life span.
- Approximately 1,200 feet of various sized hose that has failed testing.